

REFERENCE

NIST
PUBLICATIONS

NIST TIME AND FREQUENCY BULLETIN
NIST IR 6661-05

No. 641 May 2011

1. GENERAL BACKGROUND INFORMATION.....	2
2. TIME SCALE INFORMATION	2
3. BROADCAST OUTAGES OVER FIVE MINUTES AND WWVB PHASE PERTURBATIONS.....	4
4. NOTES ON NIST TIME SCALES AND PRIMARY STANDARDS.....	4
5. UTC(NIST) – AT1 PARAMETERS	5

This bulletin is published monthly. Address correspondence to:

Petrina C. Potts, Editor
Time and Frequency Division
National Institute of Standards and Technology
325 Broadway
Boulder, CO 80305-3328
(303) 497-3295
Email: ppotts@boulder.nist.gov



U.S. DEPARTMENT OF COMMERCE, GARY LOCKE, Secretary
NATIONAL INSTITUTE OF STANDARDS AND TECHNOLOGY, Patrick D. Gallagher, Director

QC

100

U56

MAY 12 2011
NIST
RESEARCH LIBRARY

1. GENERAL BACKGROUND INFORMATION

ACRONYMS AND ABBREVIATIONS USED IN THIS BULLETIN

ACTS	- Automated Computer Time Service		
BIPM	- Bureau International des Poids et Mesures		
CS	- Cesium Standard		
GPS	- Global Positioning System		
IERS	- International Earth Rotation Service		
LORAN	- Long Range Navigation		
MC	- Master Clock		
MJD	- Modified Julian Date		
NIST	- National Institute of Standards and Technology		
NOAA	- National Oceanic and Atmospheric Administration		
NVLAP	- National Voluntary Laboratory Accreditation Program		
SI	- International System of Units	ns	- nanosecond
TA	- Atomic Time	μs	- microsecond
TAI	- International Atomic Time	ms	- millisecond
USNO	- United States Naval Observatory	s	- second
UTC	- Coordinated Universal Time	min	- minute

2. TIME SCALE INFORMATION

The values listed below are based on data from the IERS, the USNO, and NIST. The UTC(USNO,MC) - UTC(NIST) values are averaged measurements from all available common-view GPS satellites (see bibliography on page 5). UTC - UTC(NIST) data are on page 3.

0000 HOURS COORDINATED UNIVERSAL TIME			
APR 2011	MJD	UT1-UTC(NIST) (±5 ms)	UTC(USNO,MC) - UTC(NIST) (±20 ns)
7	55658	-219 ms	+13 ns
14	55665	-225 ms	+12 ns
21	55672	-235 ms	+9 ns
28	55679	-241 ms	+10 ns

The master clock pulses used by the WWV, WWVH, and WWVB time-code transmissions are referenced to the UTC(NIST) time scale. Occasionally, 1 s is added to the UTC time scale. This second is called a leap second. Its purpose is to keep the UTC time scale within ±0.9 s of the UT1 astronomical time scale, which changes slightly due to variations in the Earth's period of rotation.

Positive leap seconds, beginning at 23 h 59 min 60 s UTC and ending at 0 h 0 min 0 s UTC, were inserted in the UTC time scale on 30 June 1972, 1981-1983, 1985, 1992-1994, and 1997, and on 31 December 1972-1979, 1987, 1989, 1990, 1995, 1998, 2005, and 2008.

The use of leap seconds ensures that UT1 - UTC will always be held within ±0.9 s. The current value of UT1 - UTC is called the DUT1 correction. DUT1 corrections are broadcast by WWV, WWVH, WWVB, and ACTS and are printed below. These corrections may be added to received UTC time signals in order to obtain UT1.

	- 0.2 s beginning 0000 UTC 06 January 2011
	- 0.1 s beginning 0000 UTC 03 June 2010
	+0.0 s beginning 0000 UTC 11 March 2010
	+0.1 s beginning 0000 UTC 12 November 2009
	+0.2 s beginning 0000 UTC 11 June 2009
	+0.3 s beginning 0000 UTC 12 March 2009
DUT1 = UT1 - UTC =	

The difference between UTC(NIST) and UTC has been within ± 100 ns since July 6, 1994. The table below shows values of UTC - UTC(NIST) as supplied by the BIPM in their *Circular T* publication for the most recent 310-day period in which data are available. Data are given at ten-day intervals. Five-day interval data are available in *Circular T*.

0000 Hours Coordinated Universal Time		
DATE	MJD	UTC-UTC(NIST) ns
Mar. 29, 2011	55649	10.8
Mar. 19, 2011	55639	10.3
Mar. 9, 2011	55629	9.5
Feb. 27, 2011	55619	9.4
Feb. 17, 2011	55609	9.8
Feb. 7, 2011	55599	10.2
Jan. 28, 2011	55589	9.1
Jan. 18, 2011	55579	9.1
Jan. 8, 2011	55569	8.2
Dec. 29, 2010	55559	6.7
Dec. 19, 2010	55549	5.5
Dec. 9, 2010	55539	3.9
Nov. 29, 2010	55529	0.9
Nov. 19, 2010	55519	1.1
Nov. 9, 2010	55509	-0.6
Oct. 30, 2010	55499	-1.6
Oct. 20, 2010	55489	-3.7
Oct. 10, 2010	55479	-4.6
Sep. 30, 2010	55469	-3.3
Sep. 20, 2010	55459	-0.5
Sep. 10, 2010	55449	-0.1
Aug. 31, 2010	55439	-2.2
Aug. 21, 2010	55429	-3.6
Aug. 11, 2010	55419	-5.1
Aug. 01, 2010	55409	-7.4
Jul. 22, 2010	55399	-9.4
Jul. 12, 2010	55389	-9.5
Jul. 02, 2010	55379	-10.6

3. BROADCAST OUTAGES OVER FIVE MINUTES AND WWVB PHASE PERTURBATIONS

OUTAGES OF 5 MINUTES OR MORE						PHASE PERTURBATIONS 2 ms			
Station	Apr 2011	MJD	Began UTC	Ended UTC	Freq.	Apr 2011	MJD	Began UTC	End UTC
WWVB	4-14-11	55668	1530	1622	60 kHz				
	4-25-11	55676	1735	1742	60 kHz				
WWV									
WWVH									

4. NOTES ON NIST TIME SCALES AND PRIMARY STANDARDS

Primary frequency standards developed and operated by NIST are used to provide accuracy (rate) input to the BIPM. NIST-F1, a cold-atom cesium fountain frequency standard, has served as the U.S. primary standard of time and frequency since 1999. The uncertainty of NIST-F1 is currently about 3 parts in 10^{16} .

The AT1 scale is run in real-time by use of data from an ensemble of cesium standards and hydrogen masers. It is a free-running scale whose frequency is maintained as nearly constant as possible by choosing the optimum weight for each clock that contributes to the computation.

UTC(NIST) is generated as an offset from our real-time scale AT1. It is steered in frequency towards UTC by use of data published by the BIPM in its *Circular T*. Changes in the steering frequency will be made, if necessary, at 0000 UTC on the first day of the month, and occasionally at mid-month. A change in frequency is limited to no more than ± 2 ns/day. The frequency of UTC(NIST) is kept as stable as possible at other times.

UTC is generated at the BIPM by use of a post-processed time-scale algorithm and is not available in real-time. The parameters that we use to generate UTC(NIST) in real-time are therefore based on an extrapolation of UTC from the most recent available data.

References:

Allan, D.W.; Hellwig, H.; and Glaze, D.J., "An accuracy algorithm for an atomic time scale," *Metrologia*, Vol.11, No.3, pp. 133-138 (1975).

Allan, D.W.; Davis, D.D.; Weiss, M.A.; Clements, A.; Guinot, B.; Granveaud, M.; Dorenwendt, K.; Fischer, B.; Hetzel, P.; Aoki, S.; Fujimoto, M.; Charron, L.; and Ashby, N., "Accuracy of international time and frequency comparisons via global positioning system satellites in common-view," *IEEE Transactions on Instrumentation and Measurement*, Vol. IM-34, pp.118-125 (1985).

Heavner, T.P.; Jefferts, S.R.; Donley, E.A.; Shirley, J.H. and Parker, T.E., "NIST F1; recent improvements and accuracy evaluations," *Metrologia*, Vol. 42, pp. 411-422 (2005).

Jefferts, S.R.; Shirley, J.; Parker, T.E.; Heavner, T.P.; Meekhof, D.M.; Nelson, C.; Levi, F.; Costanza, G.; De Marchi, A.; Drullinger, R.; Hollberg, L.; Lee, W.D.; and Walls, F.L., "Accuracy evaluation of NIST-F1," *Metrologia*, Vol. 39, pp. 321-336 (2002).

Lewandowski, W. and Thomas, C., "GPS Time transfer," *Proceedings of the IEEE*, Vol. 79, pp. 991-1000 (1991).

Parker, T.E.; Jefferts, S.R.; Heavner, T.P.; and Donley, E.A., "Operation of the NIST-F1 caesium fountain primary frequency standard with a maser ensemble, including the impact of frequency transfer noise," *Metrologia*, Vol. 42, pp. 423-430 (2005).

Weiss, M.A.; Allan, D.W., "An NBS Calibration Procedure for Providing Time and Frequency at a Remote Site by Weighting and Smoothing of GPS Common View Data," *IEEE Transactions on Instrumentation and Measurement*, Vol. IM-36, pp. 572-578 (1987).

5. UTC(NIST) – AT1 PARAMETERS

The table below lists parameters that are used to define UTC(NIST) with respect to our real-time scale AT1. To find the value of UTC(NIST) - AT1 at any time T (expressed as a Modified Julian Day, including a fraction if needed), the appropriate equation to use is the one for which the desired T is greater than or equal to the entry in the T_0 column and less than the entry in the last column. The values of x_{ls} , x , and y for that month are then used in the equation below to find the desired value. The parameters x and y represent the offsets in time and frequency, respectively, between UTC(NIST) and AT1; the parameter x_{ls} is the number of leap seconds applied to both UTC(NIST) and UTC, as specified by the IERS. Leap seconds are not applied to AT1.

UTC(NIST) - AT1 = $x_{ls} + x + y*(T - T_0)$					
Month	x_{ls} (s)	x (ns)	y (ns/d)	T_0 (MJD)	Valid until 0000 on: (MJD)
Jun 11	-34	-363318.2	-38.3*	55713	55743
May 11	-34	-362130.9	-38.3	55682	55713*
Apr 11	-34	-361288.3	-38.3	55660	55682
Apr 11	-34	-360980.3	-38.5	55652	55660†
Mar 11	-34	-359786.8	-38.5	55621	55652
Feb 11	-34	-359286.3	-38.5	55608	55621
Feb 11	-34	-358707.3	-38.6	55593	55608†
Jan 11	-34	-357896.7	-38.6	55572	55593
Jan 11	-34	-357508.7	-38.8	55562	55572†
Dec 10	-34	-356305.9	-38.8	55531	55562
Nov 10	-34	-355141.9	-38.8	55501	55531
Oct 10	-34	-354365.9	-38.8	55481	55401
Oct 10	-34	-353941.3	-38.6	55470	55481†
Sep 10	-34	-353285.1	-38.6	55453	55470
Sep 10	-34	-352780.7	-38.8	55440	55470†
Aug 10	-34	-351577.9	-38.8	55409	55440
Jul 10	-34	-350957.1	-38.8	55393	55409
Jul 10	-34	-350378.1	-38.6	55378	55393†
Jun 10	-34	-349760.5	-38.6	55362	55378
Jun 10	-34	-349222.9	-38.4	55348	55362†
May 10	-34	-348032.5	-38.4	55317	55348
Apr 10	-34	-346880.5	-38.4	55287	55317
Mar 10	-34	-346150.9	-38.4	55268	55287
Mar 10	-34	-345688.3	-38.0	55256	55268†
Feb 10	-34	-344624.3	-38.0	55228	55256
Jan 10	-34	-343446.3	-38.0	55197	55228

† Rate change in mid-month

*Provisional value

